

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.

7165-1288:144

Page 1 of 2

CATEGORY:

Control Units (Non High-Rise)

LISTEE:

Gamewell, 60 Pleasant Street, Ashland, MA 01721-1171
Contact: *Raymond Wood (508) 231-1400 Fax (508) 231-0900

DESIGN:

Model FLEX ALARM 620, 630, 632, 632VE, 650 and 650E fire alarm control units. Power limited, manual, automatic, local, auxiliary, remote station, *central station, proprietary, waterflow and sprinkler supervisory service. Refer to the listee's data sheet for detailed product description and operational considerations. System components:

30879	Bus Driver Module
30868, 30868-01	Initiating Modules
30878, 30878-01	Indicating Module
30870-02 through -07	Display Modules
30871, 30872	Building Control Modules
30873, 30874	Relay Modules
30869, 30940	Class A Adapter Module
30889, 30890	Power Supply Modules
30867	Processor Board
30875	City Tie Expander Module
30891	Battery Charger
30896	630 Analog Addressable Module
30897	630 Analog Addressable Expander Module
30941, 31037	650 Analog Addressable Module
30942	650 Analog Addressable Expander Module
30886	Analog Display
30894	Cabinet Expander Module
SIM-232	Dual RS-232 Port Module
ATD (Flex 650 only)	Alarm Trouble Display
RCD (Flex 650 only)	Relay Control Display
BCD (Flex 650 only)	Building Control Display
30996 (Flex 630/650 only)	Network Card
30997	Fiber Optic Module
30998	Fiber Wire Module
30979	Power Limited Adaptor
30894	Cabinet Expander Module
30999	Power Supply
LP-864	Line Protector
EVX-25, -25E, -50, -50E	Audio Amplifier
EVX-4Z, -2ZA	Zone Splitter
30993	Initiating Module
30994	AM500 Class A Adapter
*UDACT (Flex 620/630/650)	Digital Dialer
*31068, *31096	Peer to Peer Network

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

NOTE: These control units do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control units must be used with appliances that can generate the temporal pattern signal.

*Rev. 5-01-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 1, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**